

Process Control Loops at a Water Resource Recovery Facility:

Goals, Tuning, Benefits, and Interactions

Oliver Schraa^{1,3*} and Matthew Gray^{2,3}

¹inCTRL Solutions Inc., 470 Anthony Drive, Oakville, ON L6J 2K5

(*Email: schraa@inctrl.ca and Phone: 905-379-2750)

²AECOM, 625 West Ridge Pike, Suite E-100, Conshohocken, PA 19428

(Email: matthew.gray@aecom.com and Phone: 610-832-3545)

³Instrumentation & Control (I&C) Workgroup of the Municipal Resource Recovery Design Committee (MRRDC) of the Water Environment Federation (WEF)

SUBMISSION TYPE

6-12 page paper plus 30-minute presentation

KEYWORDS

Wastewater, Process Control, Sensors, Data Quality, Maintenance

ABSTRACT

WRRFs are inherently dynamic systems due to the influence of both external and internal disturbances. Disturbances cause plant performance to fluctuate and can result in plant upsets and violation of effluent discharge limits. Typical disturbances encountered in a WRRF include the following:

- Raw wastewater: flowrate, composition, concentration
- Pumping: flowrates
- Return sludge: flowrate, concentrations (COD, nitrate, phosphorus)
- Internal recycles: flowrate, concentrations (nitrate, DO)
- Supernatant return streams: flowrate, concentrations (nitrogen, phosphorus)
- Backwash: flowrate, DO
- Airflow: compressor disturbances
- Equipment failure
- Operator error

In WRRFs, process control systems are used to maintain key plant variables at or near their desired values (setpoints) and to allow the desired values to be selected to ensure safety and reliability, protect equipment, and reduce operating costs. Control systems reduce the variation in the key plant variables or control variables caused by disturbances by transferring this variability to manipulated variables

Different options are available for implementing process control within a WRRF. Process control may involve one or all of the following approaches:

- **Process design:** One of the most effective methods of control is to attenuate disturbances by incorporating appropriate plant design features. An example is the inclusion of equalization tanks to balance influent and return stream flow and concentration variations.
- **Fixed operating strategies.** These strategies typically involve using constant or proportional pumping rates and flow distributions (e.g. constant or proportional RAS and internal recycle flows, constant WAS flow, fixed step feed distribution). The settings used could be based on experience or taken from modeling studies.

- **Feedback control.** Feedback control systems use measured process output variables (controlled variables) to make automatic adjustments to process input variables (manipulated variables) using a control algorithm.
- **Model-based control.** Model-based systems use a process model to assist in the calculation of their control actions. This can range from simple model-based control calculations (e.g. waste rate calculated from SRT calculation based on average values), to feedforward/feedback control, to complex model-based feedback controllers.

This paper will discuss the impacts of these process control strategies on sensor selection, data quality control, and maintenance.

Control systems can be manual, so that operators observe the plant and implement control actions manually, or automatic control loops employing feedback or model-based control. Automatic control systems typically consist of local control loops that are managed by a supervisory control and system data acquisition system (SCADA). Potential loops include:

- Influent flow rate and flow splits
- Primary sludge pumping rate
- Phosphorus control through metal salt addition
- DO control in aeration tanks
- Ammonia control through adjustment of DO controller set point
- SRT or MLSS control through adjustment of WAS flow rate
- MLSS control through step feed
- RAS flow control
- TN or NO_x control through internal recycle adjustment and/or carbon addition
- Solids capture control in dewatering through adjustment of polymer addition

When implementing a process control system, there are several practical issues which must be considered including:

- Correct selection of sensor and actuator ranges. This is essential for good control.
- Processing of input signals or data. This may involve basic validity checks, filtering, and fault detection.
- Selection of set point limits to prevent unreasonable values especially in cascade control systems.
- Provisions for controller initialization especially when controlling variables inferred through model calculations.
- Providing limits on the control on the manipulated variable values or their rate of change.

ABOUT THE AUTHORS

Oliver Schraa is the CTO at inCTRL Solutions, and has over 20 years of experience in WWTP design and costing, process modeling and simulation, optimization, and process control. He is the chair of the WEF Biofilm Interest Group, vice-chair of the WEF I&C Workgroup, a member of the WEFTEC conference steering and program committees, a member of the WEF Modeling Expert Group, and an expert member of the IWA Design and Operations Uncertainty Task Group. Oliver contributed to the following WEF publications: Operation of Municipal Wastewater Treatment Plants – MOP 11, Wastewater Treatment Process Modeling – MOP No. 31, Nutrient Removal - MOP No. 34, and Solids Process Design and Management. *Contact:* schraa@inctrl.ca

Matthew Gray is a senior process engineer at AECOM, and has more than 15 years of professional environmental engineering experience specializing in process modelling, instrumentation and controls, energy optimization, treatability and rate testing, and design and costing of water and wastewater systems. He has evaluated, designed and implemented several successful advanced aeration systems. Mr.

Gray has presented and published several technical papers in regards to aeration design and control.

Contact: matthew.gray@aecom.com

The Authors are the Chair and Vice Chair of the WEF MRRDC I&C Workgroup. This presentation will consist of information provided by multiple members of the workgroup and will be peer reviewed by independent professionals from WEF's related committees.